

Understanding and Quantifying Arc Flash Hazards in the Mining Industry

Gerald T. Homce, P.E. and James C. Cawley, P.E., Senior Member

U.S. DHHS, CDC, NIOSH
Pittsburgh Research Laboratory
626 Cochran Mill Road, P.O. Box 18070
Pittsburgh, PA 15236 USA

Abstract - Arc flash generally refers to the dangerous exposure to thermal energy released by an arcing fault on an electrical power system, and in recent years, arc flash hazards have become a prominent safety issue in many industries. This problem however, has not been effectively addressed in the mining industry. MSHA data for the period 1990 through 2001 attributes 836 injuries to “non-contact electric arc burns”, making it the most common cause of electrical injury in mining. This paper presents results from several elements of a recent NIOSH study of arc flash hazards in mining, and provides information and recommendations that can help reduce these injuries. Characteristics of past arc flash injuries in mining are first outlined, such as the electrical components and work activities involved (based on MSHA data). This is followed by a review of important concepts and terminology needed to understand this hazard. Next, methods for identifying, measuring, and managing arc flash hazards on a power system are covered, with emphasis on recommendations found in NFPA 70E, Standard for Electrical Safety in the Workplace. Finally, results are presented from a detailed arc flash hazard analysis performed on a sample mine electrical power system using IEEE 1584-2004a, focusing on components and locations presenting severe hazards as well as engineering solutions for reducing the risk to personnel.

Index terms – electrical arcing, electrical burns, mining, arc flash hazard analysis

I. INTRODUCTION¹

Over the last 20 years or more, much progress has been made toward protecting workers from electrical arc flash hazards. In the past, this problem was often not well understood or managed, but significant advances have been made in understanding electrical arcing faults and the potential for injuries, as well as methods to quantify arc flash hazards, reduce or eliminate them, and protect workers. During the period 1992 through 2002 there was an overall decrease in the rate of electrical burns for all industries in the U.S., with industries such as construction and transportation exhibiting a significant decrease [1]. The increasing attention to arc flash hazards in recent years, including the evolution of NFPA 70E, Standard for Electrical Safety in the Workplace, may well be partially responsible for this trend [2]. Mining has seen no such sustained improvement however, with the

nonfatal electrical burn injury rate remaining constant or increasing for seven of ten years over the same period.

A recent study at the NIOSH Pittsburgh Research Laboratory looked at the issue of arc flash burns in the mining industry. To help characterize this problem, this work reviewed 836 injuries identified by the Mine Safety and Health Administration (MSHA) as “non-contact electric arc burns”, occurring from 1990 to 2001. The bituminous coal sector accounted for 55% of the injuries, followed by crushed stone and, sand and gravel at 21% and 10% respectively. Underground operations had 42% of the total, mills and plants 26%, and surface mines 22%. Predictably, the victims were most often electricians and mechanics, making up 59% of the group, but preparation plant workers and laborers were also represented. As also may be expected, the most common work activity was “electrical maintenance/repair”, but in addition to troubleshooting and repair work, a large number of arc flash incidents were caused by normal operation and subsequent failure of equipment such as circuit breakers. In addition to circuit breakers, other electrical system components commonly involved were conductors, non-powered hand tools, electrical meters, and plugs or connectors. Of the 35% of cases reporting system voltage, 84% were operating at 600V or less, and another 10% at 1000V or more.

Title 30 Code of Federal Regulations (30 CFR) contains electrical safety regulations for the mining industry [3]. Several sections of 30 CFR require personal protective equipment (PPE) such as voltage-rated gloves for certain tasks and circumstances, but there are no explicit requirements for protecting workers from arc flash hazards. With a lack of guidance on arc flash protection, one potentially effective solution is to apply the requirements found in NFPA 70E, Standard for Electrical Safety in the Workplace. The current revision of this standard contains extensive recommendations for protecting workers not only from electrical shock, but from arc flash injuries. NFPA 70E does not itself carry the force of law, but in industries monitored by OSHA (enforcing 29 CFR) it is used as a template against which to judge workplace electrical safety [4].

The scope of NFPA 70E specifically excludes certain types of power systems, including those in underground mines and powering mobile surface mining equipment. Many of its

¹ The findings and conclusions in this report are those of the authors and do not necessarily represent the views of the National Institute for Occupational Safety and Health.

concepts and requirements however, particularly those within the Safety-Related Work Practices sections, can readily be applied to protecting workers in a mining environment. More specifically, NFPA 70E offers guidance on topics such as organizing and managing safe electrical work, worker training and qualifications, safety programs, job analysis, minimizing work on energized circuits, and using proper planning, procedures, and equipment when working on energized circuits.

II. MINE POWER SYSTEM ARC FLASH HAZARD ANALYSIS

As part of recent NIOSH research examining the problem of arc flash injuries in mining, an example underground bituminous coal mine power system was analyzed to determine the presence and extent of arc flash hazards. The approach used for this analysis is found in NFPA 70E.

A. Arc flash hazard analysis requirements and approach

The most effective means to protect workers from both shock and arc flash hazards is to de-energize circuits before performing any work on or near exposed conductors. NFPA 70E stresses this point in its coverage of safety-related work practices. This standard however, also acknowledges that there are some circumstances where tasks must be performed on energized circuits, such as when troubleshooting. Similarly, 30 CFR (75.820(b)) recommends de-energizing mine power system circuits before work, but recognizes exceptions for troubleshooting and testing. NFPA 70E article 130.3 requires that if work must be done on or near energized circuits, a *flash hazard analysis* must be conducted.² A flash hazard analysis has two components, first determining the flash protection boundary, and then determining the flame resistant clothing and other PPE that is required to protect someone working inside the flash protection boundary.

Several basic concepts and definitions are key to understanding how arc flash hazards are measured, and how this information can be used to help protect personnel. Arc flash hazards are described in terms of energy, and energy is defined as the product of power and time, such as in the unit kWatt-hours used to describe electrical energy usage. An arc flash releases energy in several forms, including light energy and mechanical energy, but current analysis methods focus specifically on the thermal energy hazard to workers. The term *incident energy* is used to describe the thermal energy to which a worker is exposed in an arc flash incident, and it can be defined as the thermal energy impressed on a surface at some specified distance from the source of an arc flash. Incident energy is a function of several parameters that we can measure or calculate for a power system.

- Arcing fault current magnitude, which, depending on system voltage, may be slightly less than the bolted fault current for the same location

- Duration of the arcing fault, that is, the time it takes the system to clear the fault
- Distance from a worker to the arc
- Other factors such as conductor spacing, confinement in an enclosure, and system grounding

The most commonly used units for incident energy are calories/cm² (cal/cm²) and Joules/cm² (J/cm²).³

Another important term is *flash protection boundary*, which is defined as the distance from an arc flash source within which an unprotected person has a 50% chance of receiving a second degree burn (a curable burn).⁴ Incident energy of 1.2 cal/cm² (5 J/cm²) on unprotected skin is the generally accepted threshold for a 50% chance of sustaining a second degree burn [5]. Arc-rated clothing have an Arc Thermal Performance Value (ATPV) designation, which is the incident energy in cal/cm² (J/cm²) for which the garment can limit heat transfer to the wearer to 1.2 cal/cm² (5 J/cm²).⁵

NFPA 70E outlines two acceptable approaches for conducting a flash hazard analysis. One approach employs general guidelines and tables found in that standard (article 130.3(A) & (B), table 130.7(C)(9)(a), and table 130.7(C)(10)), that can be used to determine flash protection boundaries and PPE requirements without doing a comprehensive power system analysis. Take for example the task of removing a “starter bucket” from a motor control center on a 480 V power system branch on which a fault of 50 kA will clear in 6 cycles or less. General guidelines assign this situation a flash protection boundary of 4 ft (122 cm), and as shown in figure 1, Hazard/Risk Category 3 PPE is required for the job. *Hazard/Risk Category* (HRC) is a hazard severity classification system detailed in NFPA 70E that specifies minimum arc flash PPE based on incident energy ranges. The HRC system is summarized in figure 2. The simplified approach found in NFPA 70E however, may not be applicable to some maintenance tasks, or on power systems with available fault currents or fault clearing times outside certain limits. Additionally, these simplified methods may yield unacceptably conservative PPE requirements. Another approach is to perform more comprehensive arc flash hazard calculations involving detailed power system parameters. This approach can accurately quantify arc flash hazards on a wide range of power systems, but such an analysis can be very time consuming and costly to perform. Currently, one of the most common methods used to perform a comprehensive arc flash hazard analysis is IEEE standard 1584 -2004a, IEEE Guide for Performing Arc-Flash Hazard Calculations [6]. Commercially available power system

³ 1 Calorie = 4.184 Joules, and 1 Joule = 1 Watt-second.

⁴ The term “flash protection boundary” will be changed to “arc flash protection boundary” in the 2009 edition of NFPA 70E. This change is included in proposal 70E-39 in the *NFPA 70E Report on Proposals* at www.nfpa.org.

⁵ The arc-rating of clothing may designate Breakopen Threshold Energy (E_{BT}) instead of ATPV. This indicates that breakopen of the fire resistant material (exposing skin or underlying layers), rather than heat transfer through the material, limits the protection afforded by the clothing. See ASTM 1506-02a for more information on ATPV and E_{BT}.

² The term “flash hazard analysis” will be changed to “arc flash hazard analysis” in the 2009 edition of NFPA 70E. This change is included in proposal 70E-39 in the *NFPA 70E Report on Proposals* at www.nfpa.org

Table 130.7(C)(9)(a) Hazard/Risk Category Classifications

Task (Assumes Equipment is Energized, and Work is Done Within the Flash Protection Boundary)	Hazard/Risk Category	V-rated Gloves	V-rated Tools
600 Volt Class Motor Control Centers (MCCs) – Notes 2 (except as indicated) and 3			
CB or fused switch or starter operation with enclosure doors closed	0	N	N
Reading a panel meter while operating a meter switch	0	N	N
CB or fused switch or starter operation with enclosure doors open	1	N	N
Work on energized parts, including voltage testing	2*	Y	Y
Work on control circuits with energized parts 120 V or below, exposed	0	Y	Y
Work on control circuits with energized parts >120 V, exposed	2*	Y	Y
Insertion or removal of individual starter “buckets” from MCC – Note 4	3	Y	N
Application of safety grounds, after voltage test	2*	Y	N
Removal of bolted covers (to expose bare, energized parts)	2*	N	N
Opening hinged covers (to expose bare, energized parts)	1	N	N

Figure 1. Excerpt from NFPA 70E Table 130.7(C)(9)(a), showing the arc flash Hazard/Risk Category for removing a starter bucket from a 480 V motor control center

Hazard/risk category	Incident energy range (cal/cm ²)	General FR clothing/PPE requirements (all categories require safety glasses)
0	up to 2 *	Non-melting clothing (long sleeves)
1	>2 to 4	≥ 4 cal/cm ² -rated clothing and gloves
2	>4 to 8	≥ 8 cal/cm ² -rated clothing combination, arc-rated face shield, and gloves
3	>8 to 25	≥ 25 cal/cm ² -rated clothing combination, flash suit hood, and gloves
4	>25 to 40	≥ 40 cal/cm ² -rated clothing & flash suit combination, flash suit hood, and gloves

Figure 2. Summary of arc flash Hazard Risk Categories, based on NFPA 70E Table 130.7(C)(11) and *article 130.7(C)(5)

analysis software packages often use IEEE 1584 to assess arc flash hazards.

For the NIOSH research described in this paper, an example mine power system was assessed for arc flash hazards through a comprehensive detailed analysis, using commercially available power system analysis software applying IEEE standard 1584 techniques.

B. Example mine for an arc flash hazard analysis

MSHA data for 1993 through 2002 show that for all U.S. mining operations, 55% of non-contact electric arc (flash) burns occurred in the bituminous coal mining sector. Of the arc flash injuries in coal mining, 61% were in underground bituminous coal operations producing between 250k and 5M short tons (227k and 4.54M metric tons) per year, with almost half of these in operations producing between 250k and 1M




Figure 3. Layout of example underground coal mine used for arc flash hazard analysis

short tons (227k and 907k metric tons) per year. Based on this data, a mine producing approximately 500k short tons (454 metric tons) per year was used to represent a small underground coal mine for a mine power system arc flash hazard analysis.

Using a 500k short tons (454 metric tons) per year target, an example mine and the necessary electrical power system were designed. The mine has shaft and slope access to an 8000 ft x 8000 ft (2438 m x 2438 m) reserve with 6 ft (183 cm) seam height. The operation has 2 continuous mining sections employing room and pillar development and full retreat. Shuttle cars are used for face haulage and beltlines for main haulage. Additional details are listed in Appendix I. Figure 3 shows the mine's general layout.

C. Arc flash hazard analysis method and software

The arc flash hazard analysis for the example underground bituminous coal mine was done using a commercially available power system analysis software package. The software applies IEEE standard 1584 – 2004a to determine incident energies to which workers could be exposed during three phase power system arcing faults. Quantifying incident energy allows determination of the flash protection boundary and necessary PPE when working inside this boundary. IEEE 1584 employs an empirically-derived model for systems between 208 V and 15 kV with bolted fault currents between 700 A and 106 kA, and uses a separate theoretical model for systems above 15 kV. Other limitations apply to the use of these models, and are outlined in detail in the standard. Note that the standard focuses only on the incident energy hazard presented by an arc flash, and does not consider hazards from molten metal, projectiles, pressure waves, or toxic by-products.

Although IEEE 1584 deals primarily with the development and use of the empirical and theoretical models needed for determining arc flash hazards, it presents them within the framework of a 9 step analysis process.

- 1) Compile detailed power system information for power sources, conductors, transformers, loads, and circuit protection devices
- 2) Identify system modes of operation that provide maximum and minimum three phase fault currents
- 3) Calculate the three phase bolted fault current and X/R ratio for each point of interest on the system
- 4) Calculate arcing fault current for each point, and determine the current passing through the associated protective device(s)
- 5) Determine the duration of the arcing fault for each point, based on protective device characteristics and settings
- 6) Identify equipment voltage/class for each point to determine typical conductor spacing
- 7) Select working distance (normally assumed as the distance from conductors to a worker's face or torso)
- 8) Determine the incident energy to which a worker would be exposed, at each point
- 9) Determine the flash protection boundary at each point (normally considered to be the distance at which incident energy is 1.2 cal/cm^2 (5 J/cm^2))

It is beyond the scope of this paper to describe in detail each of the steps listed above, or the actual use of the power system analysis software, but a number of key points are listed in Appendix II to help guide the reader interested in conducting similar flash hazard analyses.

D. Arc flash hazard analysis results

Using the example mine and procedures just described, an arc flash analysis was performed to examine specific locations on a mine power system where an arcing fault could be initiated during maintenance or routine operation of equipment. Three cases are presented below. In the initial modeling of the power system, circuit protection devices were sized and adjusted to provide equipment protection and optimum system selectivity (coordination of devices for good continuity of operation). For each case, trials were run with and without motor contributions to fault current, and the condition creating the more severe arc flash hazard was used. Because incident energy is a function of available fault current, time, and distance from the arc, a lower fault current can be counteracted by the associated increase in fault clearing time and produce a higher energy. Results for each case list incident energy (IE), flash protection boundary (FPB), and hazard/risk category (HRC). Each case first lists the potential arc flash hazard for the power system in its original configuration. Then, some condition or sizing of a circuit protection device is changed to illustrate the effect on the arc flash hazard. Case 2 includes an evaluation using the NFPA 70E simplified method described earlier, as a comparison to the results obtained from the detailed analysis using IEEE 1584.

1) *7200 V switch house - Case 1:* This case considers an arcing fault on the input conductors of the first 7200 V distribution switch house downstream of the mine power borehole. Figure 4 is the switch house one-line diagram. The




Figure 4. One-line diagram for 7200 V distribution switch house in analysis case 1

fault is cleared by 50/51 electronic relays and a vacuum breaker upstream at the mine substation output.⁶

- FPB = 81 in (206 cm)
- IE = 2.6 cal/cm² (10.9 J/cm²) at 36 in (91 cm) working distance (36 in (91cm) is the default working distance for 5 kV and 15 kV class switchgear in IEEE 1584)
- HRC 1

36 in (91 cm) may not be a realistic working distance for this situation, therefore the analysis was run again with a working distance of 18 in (46 cm).

- IE = 5.2 cal/cm² (21.8 J/cm²) at 18 in (46 cm)
- HRC 2

This doubled the incident energy, increasing the HRC by one level.

Figure 5 shows an electrical hazard warning label appropriate for the above switch house. This label was automatically generated by the software used for the analysis, and includes information for arc flash and electrical shock protection.


 <h1 style="margin: 0;">WARNING</h1>	
<h2 style="margin: 0;">Arc Flash and Shock Hazard</h2> <h3 style="margin: 0;">Appropriate PPE Required</h3>	
81 inch	Flash Hazard Boundary
5.18	cal/cm² Flash Hazard at 18 inches
Category 2 Cotton Underwear + FR Shirt & Pants	
7200 VAC	Shock Hazard when cover is removed
1	Glove Class
60 inch	Limited Approach (Fixed Circuit)
26 inch	Restricted Approach
7 inch	Prohibited Approach
Bus: UGfeed SH Prot: SS out 50/51	

Figure 5. Electrical hazard warning label generated by power system analysis software, for the 7200 V switch house in case 1

2) *Slope bottom load center 600 V output – Case 2:* This case considers an arcing fault on the secondary of a load center 2-winding 750 kVA transformer, upstream of the main 600 V bus circuit breaker in that load center. This case is illustrated in figure 6 (Fault A). The fault is cleared by 8250 V 65 A current limiting fuses at the transformer primary in the load center.

- FPB = 95 in (241 cm)
- IE = 18.2 cal/cm² (76.2 J/cm²) at 18 in (46 cm) working distance
- HRC 3

A significant arc flash hazard exists at this location, and should be reduced if possible. Note that the current limiting capability of the fuses involved does not mitigate the arc flash hazard because the fault current is not high enough to cause the fuses to open in their current limiting range (current limiting clearing time of ½ cycle or less). Current limiting fuses however, can help reduce an arc flash hazard when high incident energy is due to high available fault current.

Reducing the ampere rating of the fuses clearing this fault will help to limit the hazard, although there will be some loss of selectivity in overall system protection, and nuisance tripping may become a problem. The analysis was run again with fuse size reduced from 65 A to 50 A (for the model of fuse specified for this transformer, a wide range of current ratings have the same physical size and configuration).

- FPB = 55 in (140 cm)
- IE = 7.5 cal/cm² (31.4 J/cm²) at 18 in (46 cm) working distance
- HRC 2

The smaller fuse size cuts incident energy by over 50% due to a shorter clearing time, and the HRC drops one level.

⁶ 50 and 51 are IEEE device identification numbers for instantaneous and time delay overcurrent relays, respectively.




Figure 6. One line diagram for slope bottom load center 600 V output in analysis case 2

If additional loss of selectivity and nuisance tripping can be tolerated, the hazard can be reduced even further by installing 40 A fuses, with the following results.

- FPB = 34 in (86 cm)
- IE = 3.3 cal/cm^2 (13.8 J/cm^2) at 18 in (46 cm) working distance
- HRC 1

If for some reason 80 A fuses are installed at the transformer primary at this location, analysis reveals the following (80 A is larger than needed for this application).

- FPB = 161 in (409 cm)
- IE = 43.7 cal/cm^2 (182.8 J/cm^2) at 18 in (46 cm) working distance
- Exceeds HRC 4

The potential incident energy exceeds 40 cal/cm^2 (167 J/cm^2), and any unprotected worker within approximately 13 ft (396 cm) of the arc could be seriously injured. At levels above 40 cal/cm^2 (167 J/cm^2) NFPA 70E recommends that under no circumstances should work be performed on the circuit while energized, due to the extreme hazard. Prohibiting live work however, does not completely eliminate the risk since many arcing faults are caused by electrical equipment failure during normal operation.

If the arcing fault in this load center occurs just downstream of the main circuit breaker protecting the 600 V bus, (Fault B in figure 6), the fault is cleared by that circuit breaker instead of the transformer fuses.

- FPB = 16 in (41 cm)
- IE = 1 cal/cm^2 (4.2 J/cm^2) at 18 in (46 cm) working distance
- HRC 0

Because of the reduced clearing time, the incident energy is quite low, and requires minimal protection as listed in figure 2.

As a comparison of analysis approaches, the preceding situation (where the arc flash occurs just downstream of the 600 V circuit breaker) was re-evaluated using simplified methods employing guidelines and tables in NFPA 70E instead of detailed IEEE 1584 calculations. If the task being performed on the circuit is voltage measurement or other energized work, NFPA 70E article 130.3(A) and table 130.7(C)(9)(a) specify the following.

- FPB = 48 in (122 cm)
- IE is not quantified in this method
- HRC 2, with addition of HRC 3 head/face protection⁷

The flash protection boundary and protective equipment requirements generated by this approach are very conservative compared to those indicated by a detailed analysis.

3) 2 North load center 600 V output - Case 3: Here an arcing fault occurs on the 600 V secondary of a load center 3-winding 1250 kVA transformer, upstream of the main 600 V bus breaker in that load center. The one-line diagram for this case is shown in figure 7. The load center transformer is protected by 8250 V 80 A current limiting fuses at its primary, but due to necessary coordination compromises in the original power system design, the fault is cleared by 50/51 relays and a vacuum breaker at a 7200 V switch house approximately 2000 ft (610 m) upstream.

- FPB = 175 in (445 cm)
- IE = 50.1 cal/cm^2 (209.6 J/cm^2) at 18 in (46 cm) working distance
- Exceeds HRC 4

Although the combined capacity of this 3-winding transformer suggests that 80 A fuses are required, their use and the associated adjustment of the upstream relays creates an unacceptably high arc flash hazard at the 600 V secondary.

⁷ The 2009 edition of NFPA 70E will allow the use of an arc rated face shield worn with an arc rated balaclava (sock hood) in lieu of a full switching hood (HRC 3 head/face protection). This change is included in proposal 70E-356 in the NFPA 70E Report on Proposals at www.nfpa.org.




Figure 7. One line diagram for 2 North load center 600 V output in analysis case 3

An arcing fault at this point could potentially injure unprotected workers over 14 ft (427 cm) away.

As was described in case 2, reducing fuse size may be a practical solution for mitigating an arc flash hazard if field experience shows that it will not cause unacceptable nuisance tripping. For the 2 North load center with the fuse ratings reduced from 80 A to 65 A, the fuses now clear the fault.

- FPB = 160 in (406 cm)
- IE = 43.0 cal/cm² (179.9J/cm²) at 18 in (46 cm) working distance
- Exceeds HRC 4

As can be seen from these results however, the reduction in clearing time is not sufficient to reduce the arc flash hazard to a manageable level.

Reducing the fuse size to 50 A gives the following results.

- FPB = 88 in (224 cm)
- IE = 16.3 cal/cm² (68.2 J/cm²) at 18 in (46 cm) working distance
- HRC 3

The arc flash hazard is still significant, but energized work is possible with proper precautions and protective equipment.

Another solution to the extreme arc flash hazard at the 2 North load center is the replacement of the 3-winding transformer with two 2-winding transformers, each with properly sized fuses at their primaries (separate 600 V and 995 V output transformers). This approach of course would involve a complete redesign of the load center, and so would often not be feasible on an existing system. Even for a new load center, the additional cost and space required for multiple transformers may be difficult to accommodate. If implemented however, the use of smaller fuses possible with 2 separate transformers would help reduce incident energy. In the 2 North load center for example, an individual 7200 V to 600 V 500 kVA transformer would require a 40 A fuse, resulting in the following potential arc flash hazard.

- FPB = 57 in (145 cm)
- IE = 7.9 cal/cm² (33.0 J/cm²) at 18 in (46 cm) working distance
- HRC 2

E. Important points from arc flash hazard analysis results

The arc flash hazard analysis performed on the example mine illustrates a number of important points, both about arc flash hazards on mine power systems and for such analyses in general.

- Arc flash analyses must consider all likely power system configurations and modes of operation, since the highest available fault current for a given point often does not deliver the highest incident energy
- For analysis of an existing power system, it is essential that information such as cable sizes and lengths, load characteristics, and protective device characteristics and adjustments be complete and accurate
- Coordination of power system circuit protection devices for optimum selectivity does not necessarily prevent or reduce arc flash hazards on the system
- Numerous locations on a “typical” mine power system can present arc flash hazards, with some locations having the potential for extremely dangerous arcing faults
- Arc flash hazards can be reduced in many cases by proper selection or adjustment of circuit protection devices such as fuses, although some loss of selectivity may be necessary
- The secondaries of 3-winding transformers in load centers can present arc flash hazard levels too dangerous to allow energized work under any circumstances (exceeding HRC 4)
- Some hazards may require re-engineering the power system or specific components to reduce potential incident energy to a manageable level, such as using multiple transformers instead of a single 2 or 3 winding transformer in a load center
- Notwithstanding the simplified guidelines and tables found in NFPA 70E, voltage level, available power, or equipment type cannot be used as reliable

indications of potential arc flash hazards, rather, a comprehensive analysis must be performed to positively identify and quantify these hazards

- The use of current limiting fuses does not in itself always help to reduce or eliminate arc flash hazards, since the fault current in question may be below that necessary for the fuse to operate in its current limiting range
- Equipment should be labeled to clearly communicate electrical hazards to workers
- Arc flash analyses should use realistic working distances for electrical equipment in a mining environment
- The extent and severity of arc flash hazards on mine power systems reinforces the importance of avoiding work on energized circuits except when absolutely necessary
- It is important that personnel carrying out arc flash hazard analyses thoroughly understand the process and methods involved, in order to accurately assess hazards as well as recognize suspect results

III. SUMMARY

Electrical arc flash incidents were the most common cause of nonfatal electrical injuries in the U.S. mining industry from 1996 to 2005. These incidents often occur during electrical maintenance and repair work, and involve electricians and mechanics, but they can also be the result of unexpected failure of electrical equipment such as circuit breakers during normal operation, and endanger other workers as well. Arc flash hazards are an issue that has not yet been effectively addressed in the mining industry, but intervention strategies and techniques developed in other industries over the last two decades can be applied to help solve this problem. NFPA 70E, Standard for Electrical Safety in the Workplace, is the most comprehensive and widely used source for recommendations on this topic. As part of a NIOSH study of arc flash hazards in mining, a comprehensive arc flash hazard analysis as proscribed by NFPA 70E was performed on the power system for a small

underground bituminous coal mine. The study revealed that such a power system has many locations that can endanger personnel, ranging from some requiring minimal protective arc flash rated clothing and equipment, to those that dictate major system changes or redesign to manage the flash hazard. The analysis results confirm that the mining industry needs to aggressively address the problem of electrical arc flash injuries. Prevention efforts must include better management of electrical work, including minimizing work on energized circuits, use of safe procedures for maintenance and repair work, and use of proper protective clothing and equipment, as well as consideration of arc flash hazards in power system design and maintenance, and improved employee education and training. Additionally, arc flash incidents occurring during normal operation of power system components point to a need to improve the design, installation, and maintenance of such components, as well as include arc flash hazard awareness as part of electrical safety education for all employees.

REFERENCES

- [1] Cawley, J.C., Homce, G.T., [2006] "Trends in Electrical Injury, 1992-2002", *IEEE-PCIC conference, Sept. 2006, Philadelphia, PA*, Paper No. PCIC- PH-083
- [2] NFPA Standard 70E-2004, *Standard for Electrical Safety in the Workplace*, available from NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
- [3] U.S. GPO, *Title 30-Code of Federal Regulations – 2006* (30 CFR) is available in electronic format from www.gpoaccess.gov/nara or in print from the Government Printing Office at 888-293-6498
- [4] U.S. GPO, *Title 29-Code of Federal Regulations – 2006* (29 CFR) is available in electronic format from www.gpoaccess.gov/nara or in print from the Government Printing Office at 888-293-6498
- [5] Doan, D.R., Sweigart, R.A., [2003] "A Summary of Arc Flash Energy Calculations", *IEEE Transactions on Industry Applications*, Vol.39, No.4, pp.1200, IEEE, Inc., 3 Park Avenue, New York, NY 10016-5997
- [6] IEEE Standard 1584 – 2004a, *IEEE Guide for Performing Arc Flash Hazard Calculations*, available from IEEE, Inc., 3 Park Avenue, New York, NY 10016-5997

APPENDIX I

Example Mine and Mine Power System Design Detail

- There is 1 continuous miner per section
- Total mine production is estimated at 575k raw short tons (522k metric tons) per year, based on continuous mining production estimates from existing mines in southwestern PA using two 8-hour production shifts/day, 5 production days per week, and an average development/retreat ratio of 2/1
- The power system model places both continuous miner sections near their maximum distance from the power bore hole, 4000 ft to 5000 ft (1219 m to 1524 m)
- Maximum haulage beltline length is 2000 ft (607 m)
- Maximum grade of the seam is 2.5%
- Rubber tired/battery powered equipment is used for supply and personnel transport
- The mine has a large underground equipment maintenance shop

- All underground loads are supplied by a single substation and radial distribution system (surface facilities are on their own separate substation)
- The power system conforms to current 30 CFR requirements
- The utility bus is assumed to be 1000 MVA at X/R = 10
- High voltage distribution is 7200 Vac nominal, continuous miners are 950 Vac nameplate, and all other equipment is 550 Vac nameplate except for 460 Vac loads in the underground shop
- Cables were sized using a load factor method, all motor efficiencies = 0.93, demand factor outby the East Mains @ 1 North intersection = 0.8
- Transformers are all delta-wye with high resistance grounded secondaries (15 A limit)
- Transformer taps are set to give $\leq 5\%$ voltage drop at all loads, based on a load flow study
- High voltage distribution is protected by 50/51 electronic relays and vacuum circuit breakers
- E-rated current limiting fuses protect the load center transformer primaries
- Molded case circuit breakers protect utilization voltage portable power cables

APPENDIX II

Example Mine Power System Modeling Detail

- It is assumed that any line to line fault will almost immediately escalate to involve all three phases as air ionizes across them, therefore only three phase faults are considered in the analysis (this is a general assumption in IEEE 1584)⁸
- The analysis modeled faults both without motor fault current contributions, and with 1 cycle contributions for all motors 50 hp (37.3 kW) or larger
- All mine power and trailing cable data were entered manually, using typical mining cable characteristics as published in The Mining Cable Engineering Handbook, by the Anaconda Co., 1977⁹
- A number of power system characteristics were set at the software default values, such as transformer inrush = 12X full load current for 0.1s, cable damage temperatures are 90 degree C continuous and 250 degree C maximum, and motor starting current at full voltage = 5.9X full load current for 10 s
- Arc flash maximum duration was set at the software default of 1000s (this feature allows the software user to account for a worker's reaction to move away from the arc flash, therefore, a very large value such as 1000s assumes that a worker will not react to move away prior to the fault being cleared)
- Fault current tolerances were set to -15% and +0% (these values are recommended in IEEE 1584)
- The *energy accumulation threshold* was set at 70%, to enable a software feature that checks for miscoordination of protective devices (the concept of energy accumulation accounts for multiple parallel sources of fault current that have different clearing times, and so contribute different amounts to the overall incident energy during an arcing fault)
- Vacuum breaker opening time was set to 0.300 s

⁸ It should be noted that electrical power systems in U.S. coal mines have unique design features, required by 30 CFR, that help reduce the potential for dangerous arcing faults. High resistance grounding limits the current available at a ground fault until ground fault protection de-energizes the circuit involved, greatly reducing the chance of escalation to a three phase fault. In addition, grounded shielding in large portable power cables reduces the chance of a high energy fault in the event of cable damage.

⁹ Use of product or company names does not imply endorsement by the authors, NIOSH, or the federal government.